

Costa Rica Country Update Report

Alfredo Mainieri P. and Edgar Robles F.

Instituto Costarricense de Electricidad (ICE)
P.O. Box 100032, San José Costa Rica.

Abstract

Exploration and drilling activities carried out during the last ten years in the Miravalles geothermal field allowed to extend the proven reservoir area to 20 Km². In 1994 the installation of the first 60 MW's in Costa Rica history was successfully completed, while another 55 MW unit is foreseen to start operation in 1997. Feasibility studies for units III and N are in progress, and the installation of unit III is expected in 1998.

Key Words: Costa Rica, Miravalles, Tenorio, Rincón de la Vieja, scale inhibition.




Figure 1. Costa Rica Location

TABLE 1 UTILIZATION OF GEOTHERMAL ENERGY FOR ELECTRICAL GENERATION IN DECEMBER 1994

¹ Data for 1994 if available, otherwise for 1993. Please specify which

Locality	missioner	1994	NO of units	status	Type of Unit	Unit Rating MW	Total Installed Cap. MW	Annual Energy Prod. ¹ GWh/yr	Total under Constr. or Planned MW
Miravalles	Miravalles I	1994	1	Operative	Single flash	55	55	409.5	55
Miravailes	loca de ozo I	1994	1	Operative	Back pressure	5	5	37.2	5
Miravalles	Miravalles II	1997	1	Construction	Single flash	55		@ 409.5	55
Miravalles	Miravalles III	1998	1	Programed	Single flash	55*		@409.5	
Total	4		4			170	60	1265.7	170

*No yet defined possible 55 MW

@ Estimated

Results achieved during the period 1990- 1994

After a period of forced inactivity, geothermal operations started again in 1992 and led to the installation in 1994 of 60 MW, 55 of which are produced by a single flash condensation power plant (unit I) while the remaining five MW are generated by a back pressure plant. Another 55 MW power plant (unit II) is expected to begin electric production in 1997 (see Table 1).

During this stage particular effort was devoted to the drilling of the production and reinjection wells which are needed to operate both unit I and the five back pressure MW plant. To complete the scheduled drilling programme, two rigs were utilized and total of 20 deep wells were completed between June 1992 and October 1994 (Table 2). Ten other deep wells, whose characteristics are presented by Mainieri and Vaca (1990) had

already been drilled during the 80's. Thirteen of the 20 newly drilled holes were programmed as production wells. While the remaining seven were designed for reinjection purposes. Seven of the 13 production wells, together with the previously drilled holes, either are used to get the steam needed for unit I and 5MW back pressure plant or will be utilized to feed unit U. Three production wells cannot be used because of low permeability (well PGM - 09), drilling problems (well PGM - 47) and presence of acid fluids (well PGM - 19). The latter hole, however, has an estimated production of ten MW and could be used upon acidity neutralization. Three other wells were drilled to investigate both the northern sector (PGM -14) and the southern area (PGM -28 and PGM -29) of the geothermal field and might be connected to units III and IV.

TABLE 2 WELLS DRILLED FOR ELECTRICAL AND COMBINED USE OF GEOTHERMAL RESOURCES FROM JANUARY 1, 1990 TO DECEMBER 31, 1994
(Do not include thermal gradient wells less than 100 m deep)

¹ Type or purpose of well

T = Thermal gradient or other scientific purpose

E = Exploration

P = Production

C = Combined electrical and direct use

R = Reinjection

² Total flow rates at given wellhead pressure (WHP)

Locality	Year Drilled	Well Number	Type of Well ¹	Total Depth m	Max Temp. °C	Fluid Enthalpy kJ/kg	Well Output ²	
							Flow Rate kg/s	WHP bar
Miravalles	93	4	E/P	2184	225	N.A	N.A	N.A
Miravalles	94	8	P	1200	236	1017	233	9
Miravalles	93	9	P	2001	231	N.A	N.A	N.A*
Miravalles	93	14	E/P	1396	237	1027	80	9
Miravalles	92	15	R	3022	246	N.A	N.A	N.A**
Miravalles	92	16	R	1799	225	965	59	8.8
Miravalles	93	17	P	1300	240	1100	135	9.3
Miravalles	93	19	P	1259	233	1002	146	7.5***
Miravalles	93	20	P	1700	232	1019	122	8.8
Miravalles	92-93	21	P	1715	229	990	775	10.5
Miravalles	92	22	R	1427	228	990	165	8.2
Miravalles	92	24	R	1965	228	990	110	7.3
Miravalles	94	25	R	2533	N.A	N.A	N.A	N.A
Miravalles	93	26	R	1578	214	825	69	5.4
Miravalles	94	27	R	1565	223	953	73	9.2
Miravalles	94	28	E/P	1315	228	980	185	9
Miravalles	94	29	E/P	1367	230	990	245	10.7
Miravalles	92-93	31	P	1725	243	1019	91	8.4
Miravalles	92-93	46	P	1196	239	1004	183	9
Miravalles	94	47	P	1955	234	N.A	N.A	N.A*
Miravalles	94	49	P	1309	232	960	103	9

• unproductive

** drilled 1966 deepened 1992

*** pH 3.2

N.A Not available




Figure 2. Mirovalles Geothermal Field

For the first time, air was successfully used as drilling fluid to complete the 20 holes perforated in 1992 - 1994. Upon reaching production zones, air plus water was utilized instead of mud. This procedure allowed a satisfactory recovery of cuttings and did not affect reservoir permeability which is largely controlled by fracturing.

To counteract the tendency of Mirovalles geothermal fluids to precipitate calcite, a polyacrylate inhibitor solution is injected into production wells below flashing depth. The injection is made through a 63 mm diameter capillary tubing made of 316 L stainless steel or Incoloy 825. At the surface the tube is connected to a storage and pumping system, while at its lower end it is equipped with one injection head whose weight is

changed according to the production rate and well diameter. Almost a year of continuous operation has shown that the inhibitor is working efficiently and prevents well bore Calcite precipitation

The reinjection system has also given positive results since a significant increase in well injectivity indices has occurred upon systematic reinjection of large volume of liquids. The raise in permeability of reinjection wells is likely to reflect washing out drilling residues and formation of new fractures.

TABLE 3 PRESENT AND PLANNED PRODUCTION OF ELECTRICITY

	Geothermal		Fossil Fuels		Hydro		Nuclear		Total	
	Capacity MW.	Gross Prod. GWh/yr	Capacity MW.	Gross Prod. GWh/yr	Capacity MW.	Gross Prod. GWh/yr	Capacity MW.	Gross Prod. GWh/yr	Capacity MW.	Gross Prod. GWh/yr
In operation in January 1995	60	447	156.5	701	793	3773	---	---	1009.5	4921
Under construction in January 1995	55	409.5	33	144.5	287	1481	---	---	342	1890.5
Funds committed, but not yet under construction in January 1995	55*	409.5	24	168.2	237.3	1135	---	---	349.3	1857.6
Total projected use by 2000	170	1266	213.5	1013.7	1317.3	6389.4	---	---	1700.8	8669.1

* Scheduled on 1998. possible 55 MW.

After completion of the reinjection holes PGM - 22 and PGM - 24 to the west as well as PGM - 28 and PGM - 29 to the south, however, it was proven that the production area extended in both directions. It was also established that the production area is limited by the 725°C isotherm at the reservoir top. To the east, a recent block lava flow limited, until now, exploration activities aimed at testing the possible extension of the production zone in this direction. (See figure 2).

In order to improve the exploitation of the available geothermal resource stored in the western and southern sectors of the field, feasibility studies for the installation of a third unit and possibly a fourth one are under way at present (Table 3). According to such a programme it is necessary to select suitable reinjection areas. Drilling of three new reinjection wells (PGM - 51, PGM - 52, PGM - 53 in Figure 2) has, therefore, been scheduled in the southern part of the field nearby the caldera rim. Further details are given by Mainieri and Vaca (1990).

Studies performed in Tenorio and Rincon de la Vieja volcanic areas during the 1990 - 1995 period

A prefeasibility study was carried out in the Tenorio volcano area, located about 25 Km to the south east of the Miravalles geothermal field (see Figure 3), in the frame of a programme jointly sponsored by the Italian Government and the

Description of the two operating plants

The entire geothermoelectric installed capacity of Costa Rica, i.e. 60 MW, refers the two units sited in the Miravalles geothermal field.

The main unit (unit I) is a condensation power plant with a gross capacity of 55 MW. It requires 114 Kg/s of steam at 6 bar a for its nominal capacity. Eight production wells connected to four separating units provide the steam for unit I. Six wells are used to reinject the separated brines.

The other unit is a five MW back pressure power plant requiring 19 Kg/s of steam at 7 bar a.

The available excess of steam, which is produced by the holes originally designed to feed the main unit, is currently used to operate the five MW plant. The separated brines are disposed through the reinjection system of the main unit.

Future studies and use of the field

According to the initial exploitation programme of the Miravalles geothermal field, its central part was considered to be the production zone, whereas the western and southern sectors were reserved for the reinjection of the separated brines.

United Nations. This study indicates the presence of a geothermal reservoir hosted in volcanic **racks**, with a temperature of 230 - 240°C, medium to low salinity fluids and an expected geothermal potential of 100 - 120 MW. Feasibility studies and drilling activity should start in 1996.




Figure 3 Main Geothermal Sites

Moreover I. C. E. is carrying out prefeasibility studies in the area of Rincon de la Vieja volcano, sited about 17 Km to the north west of the Miravalles geothermal field along the Guanacaste volcanic range (Figure 3). Prefeasibility studies were already carried out in this area in 1975 - 1976. Because of the subsequent inclusion of this prospecting area within the limits of a national park, no further geothermal activity can be carried out there. For this **reason** and taking into account the high geothermal potential of the area surveyed in 1975 - 1977, ICE decided to extend the geothermal investigation in the **zones** surrounding the national park. As mentioned above these prospecting are under way at present and are expected to be completed in 1995. Feasibility studies should begin in 1996. A geothermal capacity of approximately 140 MWe (hypothesizing the use of single stage turbines) was estimated for the Rincon de la Vieja **area**, in the framework of a study carried out to evaluate the national geothermal potential. Further details on this subject are given Cataldi and Mainieri (this issue).

References

- Cataldi R. and Mainieri A. (1995) Geothermal ranking and resource assessment of Costa Rica. Geothermal Resources Council Transactions (this issue).
- Mainieri A. And Vaca L. (1990) Costa Rica Country Update Report. Geothermal Resources Council Transactions, 14-I, 23-29.
- Lopez M. and Vargas H. (1994) Problemática de Suministro de Energía a Corto Plazo. I.C.E. Internal Issue.