

GEO-THERMAL DISTRICT HEATING AIR CONDITIONING PLANT AND DISTRIBUTION SYSTEM IN VICENZA

Paolo Leoni

Aziende Industriali Municipalizzate - Vicenza

Key words: geothermal water, district heating, Vicenza, Italy**Abstract**

A large low enthalpy geothermal water reservoir was discovered at about 2,000 m deep in permeable calcareous rocks by a Agip society oil exploration.

A geothermal well was drilled by Agip-Enel joint-venture in an area suited for the implementation of a district heating plant. The well produces 100 m³/h water with low contents of salts at a temperature of 67°C.

The project, undertaken by the Aziende Industriali Municipalizzate of Vicenza, a municipality owned company, foresees the exploitation of this hot resource by means of a complex and multifunctional energy system, including a district heating plant equipped with geothermal water storage tanks. The district heating plant will be remotely controlled from an existing multifunctional control station.

Commercial and residential buildings with 95 substations are connected to the system.

Efficiency system is about 1.85, fossil fuel saving (in case of gas working heat pump engines) is expected 3,341 tep/year, equivalent to 60% of existing system total consumptions. These values are referred to erogation conditions foreseen in the project.

INTRODUCTION**HEATING AND COOLING PROJECT**

The "Vicenza" geothermal heating and cooling project was developed by "Aziende Industriali Municipalizzate", a utilities company owned by the city of Vicenza, with the purpose of distributing approximately 39,900 kWh of heating energy a year, an amount which roughly corresponds to the energy needed to heat about 4,000 apartments in the northern sector of the town (table 1).

The project includes the installation of a power plant and a distribution system to exploit a geothermal water source drilled from underneath the city ground with the average temperature of 67 centigrades. It is predicted that a reduction in the consumption of conventional fuels both for heating and sanitary water will be achieved through a highly efficient thermo-dynamic system based on reversible heat pumps.

The system provides heating in the winter and air conditioning in the summer.

INSTALLATION - MANAGEMENT OF THE PLANT - TECHNICAL SUPPORT

The drilling phase of the project was undertaken and completed under a "AGIP-ENEL" (AGIP: State Owned Oil Company; ENEL: State Owned Electricity Company) joint-venture, partially financed by the European Community. The drilling phase was completed in 1983 with the opening of a well (from now on referred to as "Vicenza 1"), which stands today as the first deep-drilled well within an urban precinct in Italy.

This paper describes the utilization of the geothermal water tapped from the "Vicenza 1" deep well, the feasibility study, and the contract for the design and installation of the plant.

The project design was developed by the firm "ELC-ELECTROCONSULT" of Milan, while the actual construction was contracted out to "ASTER-ASSOCIATE TERMO-IMPIANTI", another Milano-based firm.

A.I.M. Vicenza was then and still is responsible for distributing heating gas, water and electricity within the town precinct and in the surrounding area, besides providing for other public services such as public transportation and garbage collecting. It therefore acquired the task of distributing of all energy processed and produced by the plant. The undertaking of this project by AIM falls within the larger scheme of the overall municipal energy system.


FINANCIAL MANAGEMENT

The immediate benefits provided by the project are a noteworthy reduction in conventional fuels usage, improved quality of service and the exploitation of a local, environment-friendly and self-reproducing energy source.

The total investment and operation budget is influenced by variable fuel costs, but overall investment in the project come close to 16,000 million lira (10 million dollars). Design and construction of the plant cost about 8,400 million lira, installation of the distribution network about 4,300 million lira, the construction of sub-stations about 3,300 million lira.

Recurring costs are determined by operation, maintenance, use of fuels, electricity and geothermal tax. Production income is based on the sale of heating energy, sanitary water, and cool water for air conditioning purposes.

Table 1
GEO-THERMAL
HEATING
NETWORK LAYOUT
VICENZA, ITALY



DISCHARGE TEMPERATURE OF THE GEO-WATER

It has been calculated that the variation in temperature discharge will go from a minimum of 20 °C during off seasons and 25 °C during the coldest periods. The difference between normal heating balance in the pipes (about 60 °C) and the peak temperature for heating purposes (90 °C), is such to guarantee an economically efficient use of the energy source. The expenditure of energy necessary for further decreasing the temperature is however not economically satisfactory, in the sense that it is not paid off by the heat produced.

HEATING AND COOLING PLANT

The plant has been designed to produce heating in the winter and air conditioning in the summer, through use of dual-power heat pumps. The same pumps operate with motors that can be fueled both by natural gas or by electricity. The plant was built near the geothermal well and has the following components:

- water-to-water heat pumps that run on electrically or gas-powered engines,
- supplementary boilers (3x5 Gcal/h),
- heat-to-electricity unit to interface between the geothermal water and the water in the district heating distribution pipes.
- Cooling towers connected to the heat pumps with refrigeration equipment for the summer months.
- Collection and pumping systems both for heating and cooling, pumping and storage of geothermal water.

The plant flowchart is reproduced in table 3. The sanitary water circuit requires about one sixth of the overall well capacity, the remaining 5 sixths are required for the operation of the heating distribution circuit, both through direct exchange or through the heating pumps. The heating pumps are installed one next to the other and the geothermal water goes through different cooling cycles in evaporators. The water funneled into the heating pipes is heated by condensers. The two flows operate therefore side by side but in opposite directions.

As the water comes out of the heat pumps at peak thermal use, it is heated to reach the thermal output temperature required by the system. At lower level of usage and return temperature, the water in the heating pipes is heated through a direct heat exchange with the geothermal water. A substantial contribution to the distribution capacity is also given by the "heat-recovery units" installed on the gas-powered motors.

Table 4
HEAT DURATION CURVE
OF THE DISTRICT HEATING SYSTEM




Table 5
GEOTHERMAL DISTRICT HEATING AND AIR
CONDITIONING PLANT TECHNICAL DATA

(The values are referred to output conditions as estimated in the project)

1) Thermal power installed in plant	Gcal/h	22.05	(26.2 MW)
2) Heat pump T. power	Gcal/h	5.05	(6.5 MW)
3) Gas motor recovering T. power	Gcal/h	2	(2.3 MW)
4) Gas fired boiler installed T. power	Gcal/h	15	(17.4 MW)
5) Heat supply	Gcal/year	34,300	(39,900 kWh/year)
6) Domestic hot water supply	Gcal/year	5,540	(6,400 kWh/year)
7) District heating temperature (delivery/return)			
peak level operation	°C	90/65	
8) District heating temperature (delivery/return)			
50% thermal level operation	°C	75/50	
9) Geothermal tanks	m ³	200	
10) Cooling power	Mfrig/h	2.5	
11) Cooling network temperature (delivery/return)	°C	6/12	

The heat pumps winter output is balanced by the cooling energy required during the summer by one of the major users of the system. The pipes are used for distribution of cold water during the summer as well. The reversible heat pumps allow for an extended operation schedule of the system, with related economical benefits.


Table 4 is a reproduction of the duration curve of the thermal power. It also shows the heat origin of all the equipment as determined by project specifications, while table 5 is a summary of principal technical features of plant design.

PIPE LINES AND SUB-STATIONS

The end-users are connected to the plant by a 7,400 m long double pipe network, both for heating and cooling, and by a 6,000 m supplementary single line network for sanitary water. The two lines run parallel. The hot water funneled through the pipes is used in substations located at the users' site. This is where the thermal exchange with the building water system takes place.

A technical description of a standard heating sub-station is found in table 6. The two-way regulation system is set to minimize the temperature in the pipes.

Table 6
HEATING SUBSTATION - DIAGRAM



The geothermal water is distributed directly to those users that have a centralized sanitary water treatment equipment. The standard sub-station design in table 7 require the use of a heat-exchanger geothermal-water-to-drinkable-water. The temperature in the secondary circuit is regulated around 48 °C in order to minimize heat loss.

MONITORING, MEASUREMENT AND REGULATING CRITERIA

A.I.M. Vicenza is in charge of distributing such public services as water, electricity and heating gas. The distribution networks are monitored by a centralized electronic control center. The geothermal plant and network will be connected to this system for monitoring and operational supervision. The plant itself operates on an automated control center. This minimizes local and around-the-clock supervision and personnel costs. The automated operation system allows for two types of setting:

- most efficient use of geothermal water
- most efficient use of energy for operation of compressors in the heat pumps.

Both criteria can be used for the operation of the heat pumps, for a more economic and energy efficient operation of the system, notwithstanding the amount of production power used.


The sub-stations located at the end-user site (for heat and preparation of sanitary water), are themselves equipped with an independent regulation system, with local panel and controls.

Future developments will include direct connection to the centralized remote control computer for operational monitoring and transmission of quantity of energy consumed.

The electronic transmission of such factors as temperature and other status indicators will allow for a more precise regulation of temperatures in the system, proportionally to the amount of energy required by users. Other future developments include remote operation on the sub-station for some of the most critical users and the programming of the overall system output as related to the geothermal resource.

The users' substations are equipped with local control switches that operate on the primary circuit and are set to minimize return temperatures of the heating pipe line. The remote control center will regulate in-coming temperatures in the pipes at the lowest level required by the most critical users (that is the one that requires the highest temperature). This balancing criteria has the purpose to reduce the thermal output in the pipe line as much as possible and to decrease energy consumption of the heat pumps. The transmission of major status indicators both from the plant and from sub-stations to a single centralized control center will make it possible to rationalize overall operations, monitoring and printing/storing of operational data.

Table 7
SANITARY WATER SUBSTATION - DIAGRAM



EFFICIENCY AND ENERGY SAVING

ENERGY OUTPUT

The geothermal heating system substitutes conventional heating systems, where heat is produced in furnaces of boilers located at the users' site. Therefore these conventional systems are the backdrop for determining the energy efficiency of the geothermal network.

Table 8 illustrates the operating energy outcome of the system when the pumps operate on gas.

The most remarkable data is the high value of heat discharge given by the sum of heat produced by the pumps and the heat exchanger- it equals 70% of the energy necessary for heating purposes -and the considerable savings in conventional fuels. Gas-operated motors contribute to overall savings of about 60% (3,300 tep/a) as referred to conventional systems and electricity-operated motors guarantee up to 50% savings (2,850).


Table 8 - ENERGY OUTPUT HEAT PUMPS (GAS MOTORS)					
	HEAT	H.S.W.	C	T	
NET HEAT DEMANDE	Gcal/a	33,600	5,100	2,450	41,150
EXISTING SYSTEM					
Efficiency (1)	%	76	67	69	74
Consumptions	Gcal/a	44,515	7,580	3,570	55,665
GEO System					
Distr. efficiency	%	98	92	98	
Tot. heat supply	Gcal/a	34,300	5,540	2,500	
Geoheat direct use	Gcal/a	4,440 (13%)	-		
Heat pump supply	Gcal/a	19,630 (57%)	-		
Engines recovery	Gcal/a	5,730 (17%)	-		
Boiler supply	Gcal/a	4,500 (13%)	-		
CONSUMPTIONS					
Gas boilers	Gcal/a	4,500			
Gas engines	Gcal/a	33,600			
Elec. heat pumps (2)	Gcal/a		-	1,725	
Elec. pumps (2)	Gcal/a	4,500	115	-	
TOTAL CONSUMPTIONS	Gcal/a	20,415	115	1,725	22,250
EFFICIENCY AND SAVING					
Total efficiency					1,85
Fossil fuel savings	Tep/a				3,341
Percent. savings	%				60
Elec = Electricity HEAT = Heating H.S.W. = Hot Sanitary Water C = Cooling T = Total heat and cooling demand					
(1) Average efficiency, the average boiler efficiency is 72%, while the average hospital boiler efficiency is 80% (2) The conventional thermoelectric power station specific consumption for electrical energy production is 2,300 kcal/kWh					

HEAT PUMPS OPERATION - WINTER TIME

Table 9 shows the operating diagram of the pumps during the winter time. The pumps operate on the gas-powered motor, and energy is re-used through the endothermic engine.

Table 9
WINTER OPERATION

TANDEM GROUP



Plant operation:
1 - on
2 - off
3 - on

Heat exchanger for combustion fluid cooled by aqueduct water: on.

Gas-engine and heat oil-engine recovering exchanger operating into the district heating network: on.

Cooling towers: Off.

Table 10 - PEAK LEVEL OPERATION

Plant lay-out:			Plant operations:					
gas engines 1,800 rpm			Peak 17,500,000kcal/h = 20 MW					
electric motors/generators: stand by			300 hours/year					
heat-pumps engines with copper			Delivery temperature $T_d = 90\text{ }^{\circ}\text{C}$					
evaporators (double screw compressors)			Return temperature $T_r = 65\text{ }^{\circ}\text{C}$					
boilers			District heating flow = $700\text{ m}^3/\text{h}$					
Gas-Engines			PCI = 9.45 kWh/Nm					
eng. n.	R.P.M.	mech. power kW	gas consump. Nm ³ /h	spec. consump. kWh/kWh	air consump. kg/h	cooling recov. kWt	fume recov. kWt (100%)	
1	1,800	468	144,6	2,82	2,383	502	238	
2	1,800	502	153	2,88	2,547	516	254	
3	1,800	524	158,5	2,86	2,654	524	264	
Electric Motors-Generators								
eng. n.	R.P.M.	tens. Voltage V	freq. frequency' Hz	absorbed power kW _e	effic. %	generated power kW _e	effic. %	
1	0	0	0	0	0	0	0	
2	0	0	0	0	0	0	0	
3	0	0	0	0	0	0	0	
Heat Pumps								
eng. n.	R.P.M.	evap. power kWt	Tea °C	Tua °C	eng. netpw kW _a	cond. power kWt	Tea °C	Tua °C
1	4,000	1,304.8	29.18	19.42	448	1,752.8	65.17	65.15
2	4,000	1,696.2	41.86	29.18	481,8	2,178	67.15	69.83
3	4,000	2,157.7	58.00	41.86	495	2,652.7	69.83	73.26
Boilers								
eng. n.	eng. net pw kWt	Tea °C	Tua °C	effic. %	gas cons. Nm ³ /h	air cons. Nm ³ /h	aux. abs power kW _e	
1	5,814	76.08	83.22	90				
2	5,514	83.22	90	90				
3								
Heat Exchanger HE 201								
kWt 139,5								
Tea 65 °C								
Tua 65.17 °C								


Other heat is recuperated through steam heat and from the engine oils cooling system.

Table 10 shows projected operating characteristics, at peak level (17.5 Gcal/h=20 MWt), guaranteed by the company that built the plant. Table 11 shows a chart of winter peak level operation.

Table 12 shows project data for evaporators and condensers, of the heat pumps circuits. Project data have been confirmed by actual measurements taken during plant operation.

Table 12 - TECHNICAL PROJECT DATA

	PEAK	FULL LOAD	2/3 LOAD	1/3 LOAD	1/3 LOAD
EVAPORATORS PIPELINE					
INPUT TEMPERATURE (°C)	58	58	48	47	47
OUTPUT TEMPERATURE (°C)	19,42	19,61	12,63	20,17	11,01
/T (°C)	38,58	38,39	35,37	26,83	35,99
FLOW (m ³ /h)	115	115	115	115	115
CAPACITY					
DISTRICT HEATING					
RETURN TEMPERATURE (°C)	65	65	50	45	45
CONDENSERS PIPELINE					
INPUT TEMPERATURE (°C)	65,17	65,19	53	49,10	49
OUTPUT TEMPERATURE (°C)	73,26	74,10	65,73	61,55	59,48
/T (°C)	8,09	8,91	12,73	12,45	10,48
FLOW (m ³ /h)	700	700	400	300	300
CAPACITY					
USEFUL HEAT POWER OUTPUT					
TO DISTRICT HEATING					
FROM HEAT PUMPS (kWt)	6,583	6,565	5,924	4,343	3,658



HEAT PUMPS OPERATION - SUMMER TIME

Table 13 shows a diagram for summer time operation of the system, when the pumps are powered by the electrical motor.


Table 14 is a chart of operating conditions and table 15 shows technical data as guaranteed by the company that built the plant.

The system has been used so far in the summer to provide air conditioning through cold water to the Vicenza Hospital.

Table 13

SUMMER OPERATION

TANDEM GROUP



- | | | |
|------------------------------|-----------------|---------|
| (1) Gas motor | Plant operation | 1 - off |
| (2) Electric motor/Generator | | 2 - on |
| (3) Screw compressor | | 3 - on |

CONCLUSIONS

The geothermal heating system in the town of Vicenza uses a self-reproducing energy source, a fluid at low enthalpy, that contributes in a significant manner to local energy needs both for heating and sanitary water. The water temperature was however too low for a normal heating system and it was therefore necessary to increase it to 80/90 °C. The higher temperature was obtained through the installation of heat pumps. The same heat pumps were designed to produce cool water for air conditioning in the summer for one of the major clients of the utilities circuits, and this resulted in the increased utilization of the system. The system went into operation in 1992. During the first year the most difficult aspect in the operation of the system was related to the necessity of fine tuning the heat pumps because of the very different operating conditions in the summer and winter months

Table 15

SUMMER OPERATION

Plant lay-out:
 3 gas engines 1,800 rpm
 3 electric motors/generators: stand by
 3 heat-pumps engines with copper evaporators (parallel double screw compressors)
 evaporative tower circuit

Plant operations:
 Summer 8rig/h 2,533,560 hours/year
 Delivery temperature Td = 6 °C
 Return temperature Tr = 12.1 °C
 District heating flow = 416.5 m³/h

Gas-Engines						
eng. n.	R.P.M.	mech. power kW	gas consump. Nm³/h	spec. consump. kWh/kWh	air cons. kg/h	cooling recov. kWt
						fumes recov. kWt

Gas-Engines off

Electric Motors-Generators						
eng. n.	R.P.M.	tens. Voltage V	freq. Hz	absorbed power kW	effic. X	gener. power kW
						effic. X
1	1,478	6,000	50	189.5	93.8	0
2	1,478	6,000	50	189.5	93.8	0
3	1,478	6,000	50	189.5	93.8	0

Refrigerator Groups						
eng. n.	R.P.M.	evap. power kWt	Tea °C	Tua °C	eng. net pw kW	Evaporative Towers cond. power kWt
						Tea °C
						Tua °C
						effic. -
1	3,285	982	12.1	6	172.4	1,154.2
2	3,285	982	12.1	6	172.4	1,154.2
3	3,285	982	12.1	6	172.4	1,154.2

Boilers						
eng. n.	eng. net pw kWt	Boilers °C	Tua °C	effic. X	gas consump. Nm³/h	air consump. m³/h
						aux. power kWt

Boilers off




Table 14
SUMMER OPERATION

HEATING PIPE	
COOLING PIPE	
T4	12°C RETURN WATER
T5	6°C DELIVERY WATER
T10	33.7°C WATER TOWER ENTRANCE
T11	77°C WATER TOWER EXIT

FLOW CAPACITY 415 m³/h
 1.1 g/h 1.533.000
 1.1 g/h 1.533.000